

How safe is your business? Find out by taking this quick survey.

Are fire extinguishers up to date?  
Are fire extinguishers mounted properly and free of obstruction?  
Is hood system inspected and up to date?  
Are sprinkler heads free from obstruction?  
Are fire doors properly working and free from obstruction?  
Are rolling fire door/shutters annually tested?  
Do you have an adequate number of fire extinguishers?  
Are exit doors clearly marked, lit up and free from obstruction?  
Are exit doors unlocked?  
Are all exits well lit?  
Are all electrical plates and outlets free from exposed wiring?  
Are extension cords used properly?  
Are electrical panels at least 30 inches from storage space?  
Are gas cylinders secured?  
Are hallways and storage spaces free from accumulated rubbish?  
Is storage kept a distance from the ceiling?  
Is your address properly posted?  
Is open burning prohibited?  
Are fire lanes clearly posted?  
Are combustibles kept a safe distance from any heat source?  
Are flammable liquids properly used and properly stored?  
Are employees educated in fire safety and able to use a fire extinguisher?  
Are fire drills often performed?  
Are employees aware of the location of fire extinguishers and exit doors?  
Are safety issues enforced at all times?  
Do you have a Fire Safety Plan?  
Are employees trained in this plan?  
Are hazardous materials properly labeled?  
Are hazardous materials properly disposed of?  
Is Propane Gas properly used and stored?  
Do you have current MSDS (Material Safety Data Sheets) on site for hazardous materials?

Every "yes" response indicates a positive fire safety situation, but a "no" response indicates a potential fire hazard that needs to be corrected. If you have any questions, please call Fire Prevention at 440-974-5768.