

ADDENDUM NO. 1

TO: All Prospective Bidders

FROM: City of Mentor
8500 Civic Center Blvd.
Mentor, Ohio 44060

SUBJECT: City of Mentor Senior Center HVAC Upgrade Project

DATE: November 17, 2016

This Addendum forms a part of the contract documents and modifies the original bidding documents dated November 9, 2016. **Acknowledge receipt of this addendum below and include this form in your proposal documents.** Failure to do so may subject the bidder to disqualification.

BID DOCUMENTS

Return this completed form with your bid.

The existing return fan for Air Handler #1 shall be removed and replaced with a new fan/motor assembly with a VFD. Contractor shall provide new fan/motor assembly, remove and replace existing fan/motor, perform all electrical and sheet metal work, along with controls required to tie in and program the automation system.

Specs on existing return fan:

CentriMaster
Model # XB300M 200/3 ODP W/HSI300 W/MCP300
Serial # STC445101
H.P. 3
Volts 208/230/480
60 HZ
PH. 3
Size of existing fan assembly: 45"x45"x58"

ACKNOWLEDGEMENT:

Name of Bidder

Date

Signature

Title